

Noise Monitoring Data-Monthly Summary						
Month and Year:	Apr-19					
Project:	Central Station Main Works					
EPL Licence Number:	21148					
EPL Weblink:	<a href="https://centralstationmetro.com/documents/">https://centralstationmetro.com/documents/</a>					
Specific EPL Monitoring Condition:	M7.1- Noise Monitoring					
Monitoring Location:	Number of Monitoring Events during the Month	Attended/Continuous Monitoring	Event Based Monitoring? (Y/N)	Measured Parameter: LAeq15mins (dB)	Predicted Parameter: LAeq15mins (dB)	Comment
Chalmers St	3	Continuous	Yes	66	62	Ambient train noise; truck/plant reversing noise from the road, not associated with LOR work; train safety horn; no obvious sound of construction works; jackhammering barely audible
Chalmers St	4	Attended	Yes	66	69	Hoarding works commenced. Unloading activities underway. Ped traffic audible in close proximity to measuring location.
YHA (P1)	2	Attended	Yes	63	77	Train idling on Platform 1 contributing to larger exceedance. Multiple station announcements. Birds. Aircraft. Work at the stairs and in the rail corridor were not audible.