

Noise Monitoring Data-Monthly Summary

Month and Year:	Aug-19					
Project:	Central Station Main Works					
EPL Licence Number:	21148					
EPL Weblink:	https://centralstationmetro.com/documents/					
Specific EPL Monitoring Condition:	M7.1- Noise Monitoring					
Monitoring Location:	Number of Monitoring Events during the Month	Attended/Continuous Monitoring	Event Based Monitoring? (Y/N)	Measured Parameter: LAeq15mins (dB)	Predicted Parameter: LAeq15mins (dB)	Comment
Chalmers St	30	Continuous	Yes	Max 75	77	One 15min period over prediction, works were stopped as a result. All other works meet predictions.
Regent St	1	Continuous	Yes	Max 60.4	60	Sydney Trains Possession.