

Noise Monitoring Data-Monthly Summary						
Month and Year:	Jul-19					
Project:	Central Station Main Works					
EPL Licence Number:	21148					
EPL Weblink:	https://centralstationmetro.com/documents/					
Specific EPL Monitoring Condition:	M7.1- Noise Monitoring					
Monitoring Location:	Number of Monitoring Events during the Month	Attended/Continuous Monitoring	Event Based Monitoring? (Y/N)	Measured Parameter: LAeq15mins (dB)	Predicted Parameter: LAeq15mins (dB)	Comment
Chalmers St	56	Continuous	Yes	Max 70	72	Compliant with R4.3
Dental Hospital – SW corner of building, office area next to stairs	1	Attended	Yes	60	60 (internal)	Bounce Hotel Demolition work – concrete breaking (jackhammering) using 5t excavator and 4.5t hammer. LAeq15min exceeded 60dB (plus 5dB penalty for annoying charecteristics), however < 6.5hrs. Compliant.
Univerity Preparation College	1	Attended	Yes	61	60 (internal)	Internal noise compliance check with UPC against CoA E37/38
YHA (platform 1)	1	Attended	Yes	53	72	Activities were breaking with a small excavator while breaking with a hand breaker on platform 8/9 in FT13.