

Noise Monitoring Data-Monthly Summary						
<b>Month and Year:</b>	Oct-19					
<b>Project:</b>	Central Station Main Works					
<b>EPL Licence Number:</b>	21148					
<b>EPL Weblink:</b>	<a href="https://centralstationmetro.com/documents/">https://centralstationmetro.com/documents/</a>					
<b>Specific EPL Monitoring Condition:</b>	M7.1- Noise Monitoring					
<b>Monitoring Location:</b>	<b>Number of Monitoring Events during the Month</b>	<b>Attended/Continuous Monitoring</b>	<b>Event Based Monitoring? (Y/N)</b>	<b>Measured Parameter: LAeq15mins (dB)</b>	<b>Predicted Parameter: LAeq15mins (dB)</b>	<b>Comment</b>
Chalmers St	34	Continuous	Yes	Max 58	72	LAeq15min below 60dB at Chalmers. CSM works barely audible.
Regent	1	Continuous	Yes	Max 55	60	CSM works inaudible.
YHA	1	Continuous	Yes	Max 55	65	CSM works inaudible.