

Noise Monitoring Data-Monthly Summary						
Month and Year:		Jan-20				
Project:		Central Station Main Works				
EPL Licence Number:		21148				
EPL Weblink:		https://centralstationmetro.com/documents/				
Specific EPL Monitoring Condition:		M7.1- Noise Monitoring				
Monitoring Location:	Number of Monitoring Events during the Month	Attended/Continuous Monitoring	Event Based Monitoring? (Y/N)	Measured Parameter: LAeq15mins (dB)	Predicted Parameter: LAeq15mins (dB)	Comment
Chalmers St	22	Continuous	Yes	Max 68	74	LOR works include hoarding installation on platform 20/21 and hydrant excavation, saw cutting and hammering. Works barely audible.
Chalmers St	4	Attended	Yes	Max 71	(internal noise criteria; <60dB for <6.5hr (50% of the time between 07:00-20:00))	Monitoring conducted inside Haven Specialty Coffee Café during breaking out of stabilised sand and reconfiguring piling pad at Eastern Entrance. Complies with internal noise criteria.
YHA	16	Continuous	Yes	Max 65	60	CSM works occurring in the Northern Concourse and Suburban Platforms from time to time, however only train idling audible.
54 Regent St	7	Continuous	Yes	Max 49	58	Truck movements on SYAB.