

Water Treatment Plant - Water Discharge Monitoring Data Summary						
Month and Year	December 2018 to December 2019					
Project	Central Station Main Works					
EPL Licence Number	21148					
EPL Web link	https://centralstationmetro.com/documents/					
Specific EPL Monitoring Condition:	M2.1- Pollutant Discharge					
Date	Discharge Point 1 = Stormwater 2 = Land	M2.3 Special Frequency 1; Less than 24 hours prior to controlled and daily discharge (Y/N)	pH 6.5 - 8.5	TSS <50 mg/L	Oil and grease present (Y/N)	Comments
2/09/2019	2	Y	8.0	12	N	
10/09/2019	2	Y	8.5	7	N	
14/09/2019	2	Y	8.1	29	N	
17/09/2019	2	Y	7.6	46	N	
18/09/2019	2	Y	7.9	43	N	
18/09/2019	2	Y	8.1	47	N	
18/09/2019	2	Y	8.3	46	N	
19/09/2019	2	Y	7.2	42	N	
19/09/2019	2	Y	8.1	39	N	
19/09/2019	2	Y	7.9	36	N	
20/09/2019	2	Y	7.8	42	N	
20/09/2019	2	Y	7.6	44	N	
21/09/2019	2	Y	7.2	46	N	

No discharges from the Water Treatment Plant via discharge point 1 to the stormwater system during the reporting period. All stormwater was managed within the project EPL boundary.